1708001 DATA SHEET

valid from: 2021-09-01

J-Y(ST)Y...LG Fire Alarm Cable



Application

J-Y(ST)Y...LG Fire Alarm Cable is used to transmit signals and can be used for fixed installation on and under plaster, in dry and damp

For outdoor use this cable should be installed under plaster only.

Design

Outer sheath

Design acc. to DIN VDE 0815, Table 4

Type J-Y(ST)Y...LG

Certification Classification of fire behaviour

according to EN 13501-6 and EN 50575

(article/dimension range see www.lappkabel.com/cpr)
Colour of the sheath: flame red (similar RAL 3000)

Electrical properties at 20 °C

 $\begin{array}{lll} \mbox{Loop resistance} & \mbox{max. 73.2 } \ensuremath{\Omega/km} \\ \mbox{Insulation resistance} & \mbox{min. 100 M} \ensuremath{\Omega/km} \\ \end{array}$

Mutual capacitance max. 100 nF/km (at 800 Hz)

Inductance ca. 0.65 mH/km

Capacitive coupling max. 300 pF/100 m (at 800 Hz)

Maximum operating voltage 300 V (not for power applications)

Must not be connected to the mains supply voltage.

Test voltage C/C: 800 V

C/S: 800 V

Mechanical and thermal properties

Minimum bending radius fixed installation: 10 x outer diameter

Temperature range occasional flexing: -5 °C up to +50 °C max. conductor temperature

fixed installation: -30 °C up to +70 °C max. conductor temperature

Flammability flame retardant acc. to EN 60332-1-2 resp. IEC 60332-1-2

Tests acc. to DIN VDE 0815, Type J-Y(ST)Y...LG

Electrical properties acc. to table 10 Tests at the cable acc. to table 21

General requirements These cables are conform to

EU-Directive 2014/35/EU (Low Voltage Directive) and to EU-Directive 2011/65/EU (RoHS, Restriction of the use of certain

hazardous substances).

These cables (see www.lappkabel.com/cpr) are classified in accordance with the EU-Regulation no. 305/2011 (CPR).

Environmental information These cables meet the substance-specific requirements of the EU Directive 2011/65/EU (RoHS).

Note Trade product, no Lapp product

Creator: PESA / PDC Document: DB1708001EN

Released: ALTE / PDC Version: 02

Page 1 of 1